

DOUBLE STEPS  
REQUIRED IN 3'  
RISER ABOVE  
SAFETY PLATFORM

8" MIN.

30"  
OPENING

SAFETY  
PLATFORM


7' MIN. BELOW PLATFORM

8' MIN. TO 10' MAX.

**NOTES**

1. SEE STANDARD PRECAST MANHOLE FOR TYPICAL DETAILS.
2. FOR MANHOLES 16 FEET OR GREATER IN DEPTH.

SAFETY  
PLATFORM



**BARTOW COUNTY, GEORGIA**  
BARTOW COUNTY WATER SYSTEM  
TELEPHONE (770) 387-5170

**SEWER DETAILS**  
**MANHOLE WITH SAFETY PLATFORM**

DRAWN BY: DVK

SCALE: NTS

DATE: DEC. 20, 2003

DWG. NO.: SEW-9