

**Request For Bids
Generator Purchase and Installation
Addendum 1**

A pre-bid walkthrough of the generator sites will be held at 2 PM on Thursday, January 14. Please meet at Fire Station 7 located at 30 West Main St, Kingston, GA 30145. Deputy Fire Chief Marcus Warren will be onsite for the walkthrough.

This walkthrough is not required to submit a bid but is available should you need additional information to create an accurate quote.

Suggested Generator Specifications:

Each generator should be able to power a fire station for a minimum of 24 hours.

<u>Station 5</u> 19 West Rocky St White, Ga 30184	50KW Natural Gas Generator 200amp Nema 3R Transfer Switch
---	--

<i>Running Load (KW)</i>	40
<i>Starting Load (KW)</i>	40
<i>Generator Specified (KW)</i>	48
<i>Generator Voltage</i>	240
Single Phase	
Automatic controls	
<i>Fuel type</i>	Natural Gas

<u>Station 7</u> 30 W. Main St Kingston, Ga. 30145	50KW Natural Gas Generator 200amp Nema 3R Transfer Switch
--	--

<i>Running Load (KW)</i>	40
<i>Starting Load (KW)</i>	40
<i>Generator Specified (KW)</i>	48
<i>Generator Voltage</i>	240
Single Phase	
Automatic controls	
<i>Fuel type</i>	Natural Gas

<u>Station 15</u> 2124 Highway 140 Adairsville, Ga. 30103	60Kw Diesel Generator 200 amp Nema 3R Transfer switch
---	--

<i>Running Load (KW)</i>	40
<i>Starting Load (KW)</i>	40
<i>Generator Specified (KW)</i>	48
<i>Generator Voltage</i>	240
Single Phase	
Automatic controls	
<i>Fuel type</i>	Diesel