

Request For Bids Generator Purchase and Installation

Bartow County is requesting a quote for the purchase and installation of three generators for backup power needs at three fire stations. The generators will be installed at Fire Station 5, Fire Station 7, and Fire Station 15.

The information below summarizes the generator needs of each fire station according to a certified electrician.

Fire Station 5 (19 West Rocky Street, White, GA 30184)

Running Load (KW)	40
Starting Load (KW)	40
Is load being stepped in?	No
Generator Specified (KW)	48
Generator Voltage	240
Single or Three Phase	Single
Type of Controls	Automatic
Type of Fuel	diesel

Fire Station 7 (30 West Main St, Kingston, GA 30145)

Running Load (KW)	40
Starting Load (KW)	40
Is load being stepped in?	No
Generator Specified (KW)	48
Generator Voltage	240
Single or Three Phase	Single
Type of Controls	Automatic
Type of Fuel	diesel

Fire Station 15 (2124 Hwy 140 NW, Adairsville, GA 30130)

Running Load (KW)	40
Starting Load (KW)	40
Is load being stepped in?	No
Generator Specified (KW)	48
Generator Voltage	240
Single or Three Phase	Single
Type of Controls	Automatic
Type of Fuel	diesel

This project is funded in part with a federal FEMA Hazard Mitigation Program grant and any work completed will need to adhere to grant guidelines.

To be considered for this project, quotes are due: Monday, January 18, 2021 by 2:00 P.M. Quotes may be submitted electronically to cantrelli@bartowga.org.